

Himachal Pradesh Public Works Department

No.PWU/CB/WA/ B-6/2020-21
To,

15 297-98 Dated:-

8 2/21


✓ The Principal,
Scholars Unified Public School
Village Arniala,
Tehsil & Distt. Una (H.P)

Subject: - Regarding issue of Building safety Certificate 2020-21.


In this connection, it is intimated that the subject cited building of Scholars Unified Public School situated at Village Arniala Tehsil & Distt.Una, has been visited & inspected by the concerned Assistant Engineer. At the time of inspection it has been found that structural drawings were not got approved from the competent Govt. certified engineer. Moreover no any kinds of technical assistance has been taken from PWD authorities during the construction of the building. It is therefore, the structural safety of this building may not be ensured specifically from earthquake resistance point of view. Hence this department would not be held responsible for any type of loss of life and property etc, if this structure fails under any unforeseen circumstances.

However as per the visual inspection it has been observed that the existing building as per the drawings produced during inspection seems to be safe at present under normal circumstances only for the year 2021-22. No Officer/ official of this department would attend any plea in any Hon,ble Court of law for any type of dispute and claim and loss.


This certificate is only for official use and not for legal purpose


**Executive Engineer,
Una Division, HP.PWD,
Una.**

Copy to the Assistant Engineer, Una Sub-Division No-I HP,PWD Una for information with reference to his office letter No. 3385 Dated 03-02-2021.


**Executive Engineer,
Una Division, HP.PWD.,
Una**




**President
Vibrant Vivekananda Educational
Society, Una (H.P.)**